



CERTIFICATE OF TESTING

Work Order No. r WO/ETL/053/07-08
Date ; 27.08.2007

CERTIFICATE No. : CT/ETL/032/07-08
Date of Testing : 07.09.2007 to 13.09.2007
Page No.: 1 of 7

Test Item: Test Terminal Block a. 3 phase 4 wire Front Connected -3DA-1 No.
b. 3 phase 4 wire Back Connected -50A-2 No.
c. 3 phase 3 wire Back Connected -50A-1 No.

Tested for M/S. DEEPL Electricals Pvt. Ltd. Gala No. 14, Ground Floor,
Aghadi Industrial Estate, Marol Maroshi Road, Andheri (E), Mumbai- 400 059

Tested at: IDEMT, Mumbai. 400 022


Specification of items Under Test	Specification of Standards Used
Manufacturer : M/s, Deepl Electrical Pvt. Ltd. Mumbai-59 Condition of Item on receipt : Good Range /Rating / Size : a) 3GA b) 50A c) 50A Model/Markings, Sr.No.: a) Deepl Elect, (P) Ltd. 3 phase -4VWre1100V 30 A b) Deepl Elect (P) Ltd. 3 phase 4 wire 110 00 V 50A c) Deepl Elect. (P) Ltd. 3Phase3wire 1100V 50 A Accuracy : N.A	1) RE High voltage tester Range 0 to 5KV.AC Acc: $\pm 2.5\%$ 2) GANZ Insulation Tester Range: 0 To 1Q.000M Ohms Acc: $\pm 2.5\%$ 3) Fluke" Thermocouple Thermometer, Model-54 It Range: -200°C to +1372°C (Type K) Acc: $\pm (0.05\% \text{ at } 100^\circ\text{C} + 0.3^\circ\text{C})$ 4) Zaran High Current Test Set (0-50QA) 5) Environmental Chamber Blue Star Tenry Chamber (Dry Heat Damp Heat) Temp: -65 to 200 C humidity 35% to 95%

Ambient Conditions :

Temperature : $25^\circ\text{C} \pm 2.5^\circ\text{C}$ Relative Humidity : 35% to 65%

Remarks : Please refer page 2 to 7 for Test Results.

- 1) Procedure of Test : The above mentioned item, is tested as per Customer Request
- 2) Total Uncertainty in Measurement at 95% CL N.A.


S.G.KHALADKAR
QUALITY MANAGER
AUTHORISED SIGNATORY

(Note : This certificate refers only to the particular item(s) submitted for testing. The certificate should not be reproduced except in full without the prior permission from the Principal Director IDEMT, Mumbai - 400 022)

A GOVERNMENT OF INDIA SOCIETY
वैद्युतिक मापन उपयंत्र अभिकल्प संस्थान
Institute for Design of Electrical Measuring Instruments

SWATANTRYAVEER TATYA TOPE MARG, CHUNABHATTI, SION P.O. MUMBAI - 400 022.
स्वातंत्र्यवीर तात्या टोपे मार्ग, चुनाभट्टी, सायन डाकघर, मुंबई-400 022.



वैधुतिक मापन उपयंत्र अभिकल्प संस्थान, मुंबई - 400 022.

INSTITUTE FOR DESIGN OF ELECTRICAL MEASURING INSTRUMENTS, MUMBAJ - 400022.

ELECTRICAL TESTING LABORATORY

Certificate for Sr. No: -

Certificate No.: CT/BTU032/07-QS

Date of Testing: 07.09.2007 to 13.09.2007

Page No.: 2 of 7

Test Result of: a) 3- Phase- 4 Wire Terminal Block (Front Connected) 30A- INo.

1. Markings:

Mould Marking on front Side : Test Terminal Block 3 phase 4 wire
of Terminal Block Cover DeepL Electrical Pvt. Ltd.
1100 Volts - 30 A

2. Insulation Resistance Test:

After applying 500V DC between the points given below for one Minute the IR value measured were as follows.

- i) Between two live Terminals - 1000 M-ohm
- ii) Between terminals shorted together & body - 1000 M-ohm

3. Di -electric Strength Test:

An AC, 2.5 KV, 50 Hz RMS was applied between the points given below for one minute. It withstood the High Voltage.

- i) Between two live terminals
- ii) Between all terminals shorted together & body

4. Insulation Resistance at 40°C

Terminal Block was kept in the chamber and Temperature was adjusted to 40°C and it was maintained for 1 hour and at the end of one hour applying 500V DC between the points given below for one Minute the IR Value measured were as follows.

- i) Between two live Terminals - 5000M-ohm
- ii) Between all terminals shorted together & body - 5000M-ohm

CHECKED BY 

TESTBDfivC 



वैधुतिक मापन उपयंत्र अभिकल्प संस्थान, मुंबई - 400 022.

INSTITUTE FOR DESIGN OF ELECTRICAL MEASURING INSTRUMENTS, MUMBAI - 400022.

INSTITUTE FOR DESIGN OF ELECTRICAL MEASURING INSTRUMENTS, MUMBAI - 400022.

ELECTRICAL TESTING LABORATORY

ELECTRICAL TESTING LABORATORY

Certificate for Sr. No.: -

Certificate No.: CT/ETL'0J2/Q7-G8

Date of Testing: 07.09.2007 to 13.09.2007

Page No.: 3 of 7

Date of Testing: 07.09.2007 to 13.09.2007

Page No.: 3 of 7

Test Result of: a) 3- Phase- 4 Wire Terminal Block (Front Connected) 30A- INo

Test Result of: a) 3- Phase- 4 Wire Terminal Block (Front Connected) 30A- INo

5. **Insulation Resistance at Dry Heat (80°C)**

The chamber was adjusted to 80°C and then Terminal Block was kept their for one hour and at the end of one hour applying 500V DC between the points given below for one Minute the IR Value measured were as follows.

- i) Between two live terminals - 5000 M-ohm
- II) Between all terminals shorted together & body - 5000 M-ohm

6. **Temperature Rise Test**

Temperature rise was measured at 30 Amp. Current (till stable tetnp was achieved) at the following points.

Ambient Temp: 28°C

- a) Terminal for external insulated conductor - 21°C
- b) External enclosure - 10°C

CHECKED BY

TESTED BY



वैद्युतिक मापन उपयंत्र अभिकल्प संस्थान, मुंबई - 400 022.
INSTITUTE FOR DESIGN OF ELECTRICAL MEASURING INSTRUMENTS, MUMBAI - 400022.

ELECTRICAL TESTING LABORATORY

Certificate for Sr. No.: -

Certificate No.: CT/ETL/032/07-08

Date of Testing: 07.09.2007 to 13-09.2007

PageNo.: 4 of 7

Test Result of: b) 3- Phase- 4 Wire *Terminal* Block (Back Connected) 50A- 2Nos.

1. Markings:

Mould Marking on front Side : TesL Terminal Block 3 phase 4 wire
of Terminal Block Cover Deepl Electrical Pvt. Ltd.
" 1100 Volts -5QA

2. Insulation Resistance Test:

After applying 500V DC between the points given below for one Minute the IR value measured were as follows.

- i) Between two live Terminals - 2000 M-ohm
- ii) Between terminals shorted together &, body - 1500 M-ohm

3. Pi -electric Strength Test:

An AC, 2.5 KV, 50 Hz RMS was applied between the points given below for one minute. It with stood the High Voltage.

- i) Between two live terminals
- ii) Between all terminals shorted together & body

4. instilaiioc Resistance at 40°C

Terminal Block was kept in the chamber and Temperature was adjusted to 40°C and H was maintained for 1 iour and at the end of one hour applying 500V DC between the points given below for one minute the IR. Value measured were as follows.

- i) Between two live Terminals - 5000M-ohm
- ii) Between all terminal shorted together & *body* - 5000M-obm

CHECKED BY

TESTED BY



वै^ तिक मापन उपयंत्र अभिकल्प संस्थान, मुंबई -400022.

INSTITUTE FOR DESIGN OF ELECTRICAL MEASURING INSTRUMENTS, MUMBAI - 400022.

ELECTRICAL TESTING LABORATORY

Certificate for Sr. No.: -

Certificate No.: CT/ETfy032/07-08

Date of Testing: 07.09.2007 to 13.09.2007

Page No.: 5 of 7

Test Result of: b) 3- Phase- 4 Wire Terminal Block (Back Connected) 50A~ 2Nos

5. Insulation Resistance at Dry Heat (80C)

The chamber was adjusted to 80°C and then Terminal Block was kept their for one hour and at the end of one hour applying 500V DC between the potnis given below for one Minute the IR Vaieu measured were as follows.

- i) Between two live terminals - 5000 M-ohm
- ii) Between all terminals shorted together & body - 5000 M-ohm

6. Temperature Rise Test


Temperature rise was measured at 50 Amp. Current (fill stable temp was achieved) at the following points.

Ambient Temp: 23°C

- c) Terminal for external insulated conductor - 22°C
- d) External enclosure - 10°C

CHECKED BY

TESTED BY



INSTITUTE FOR DESIGN OF ELECTRICAL MEASURING INSTRUMENTS, MUMBAI - 400022.

ELECTRICAL TESTING LABORATORY

Certificate for Sr. No.: -

Certificate No.: CT/ETL/032/07-08

Date of Testing: 07.09.2007 to 13.09.2007

Page No.: 6 of 7

Test Result of: c) 3- Phase- 3 Wire Terminal Block (Back Connected) 50A- INos.

1. Markings:

Mould Marking on front Side : Te^t Terminal Block 3 phase 3 wire
of Terminal Block Cover Deepl ElectricaU Pvt. Ltd.
1100 Volts-50A

2. Insulation Resistance Test:

After applying 500V DC between the points given below for one Minute the IR value measured were as follows.

- i) Between two live Terminals - 1000 M-ohm
- ii) Between terminals shorted together & body - 1000 M-ohm

3. Di -electric Strength Test:

An AC, 2.5 KV, 50 Hz RMS was applied between the points given below for one minute. Ji withstood the High Voltage.

- i) Between two live terminals
- ii) Between all terminals shorted together & body

4. Insulation Resistance at 40°C

Terminal Block was kept in the chamber and Temperature was adjusted to 40^DC and ii was maintained for 1 hour and at the end of one hour applying 500V DC between the points given below for one Minute the IR Value measured were as *follow s*.

- i) Between two live Terminals - $5000M^{\circ}ohm$
 ii)-Between-alUexniinaUhorted together & body - $5000M\text{-ohm}$

f'HECKL-D BY

XV $\wedge / H \sim \wedge' \wedge$

TESTED BY:

Handwritten signature



वैधुतिक मापन उपयंत्र अभिकल्प संस्थान, मुंबई - 400 022.
INSTITUTE FOR DESIGN OF ELECTRICAL MEASURING INSTRUMENTS, MUMBAI - 400 022.

ELECTRICAL TESTING LABORATORY

Certificate for Sr. No.: --

Certificate No.: CT/ETL/032/07-08

Date of Testing: 07.09.2007 to 13.09.2007

Page No.: 7 of 7

Test Result of: c) 3- Phase- 3 Wire Terminal Block (Back Connected) 50A- 1Nos

5. Insulation Resistance at Dry Heat (80°C)

The chamber was adjusted to 80°C and then Terminal Block was kept their for one hour and at the end of one hour applying 500V DC between the points given below for one Minute the IR Value measured were as follows.

- i) Between two live terminals – 5000 M-ohm
- ii) Between all terminals shorted together & body – 5000 M-ohm

6. Temperature Rise Test

Temperature rise was measured at 50 Amp. Current (till stable temp was achieved) at the following points.


Ambient Temp : 22°C

- e) Terminal for external insulated conductor - 16°C
- f) External enclosure - 3°C


CHECKED BY



TESTED BY

3f1/ 4W (OLD) FRONT CONNECTED PANEL FIXING HOLES DIMENSIONS




30/ 4W (OLD¹) BACK CONNECTED PANEL CUT OUT VIEW






3ø/ 4W (MINI) FRONT CONNECTED PANEL FIXING HOLES DIMENSIONS




D-125, Ansa Industrial Estate, Saki Vihar Road, Mumbai - 400 072, INDIA
Tel.: 91-22-66963613 / 28581158, Fax: 022-26864814 / 66963614
E-mail: anjani.agarwal@gmail.com

TEST TERMINAL BLOCK - SUITABLE FOR 3 PHASE 3 WIRE
AND ALSO 3 PHASE 4 WIRE (COMMON COUTPUT)



D-125, Kalyaneshwari Road, Sakinaka Road, Mumbai - 400072, INDIA
M: 09-22-883633 / 2051113; Fax: 022-26664834 / 6662654
E: info@kapurandpaul.com



Address: D125, Ansa Industrial Estate, Saki Vihar Road, Saki Naka, Mumbai 400072,
India

Tel:-Off: 2858 1158

Res: 28570829/2623 6011

Fax: 28570829/2623 6011

Mobile: 9324421029 / 9324236011

Website: www.deepl.co.in